


THE CITY OF
POMONA

Development Services Department



February 12, 2024

James Kercheval
490 Preciado St.
Pomona, CA 91768

Subject: Notice of Decision for File No. MINCOA 000178-2024

Dear James Kercheval,

The Planning Division has reviewed your Certificate of Appropriateness application to install a PV system on the roof of the primary structure located at **490 Preciado St.** Upon review of the City's historic preservation ordinance and design guidelines your project has been **approved**. The attached decision letter provides the analysis and basis for the decision.

All Minor Certificates of Appropriateness applications include a 20 day appeal period following the date of approval. The appeal period for this application will expire on March 04, 2024. The applicant or any member of the public may file an appeal. In the event that an appeal is submitted to the City, Planning staff will contact you to discuss the appeal. **If there are no appeals, please contact the Building and Safety Division as early as March 05, 2024 to submit and pull a building permit for the installation of the proposed PV system.** Please attach this letter to all required building permit applications as proof of MINCOA approval.

If you have any questions, please contact me at carlos.molina@pomonaca.gov.

Sincerely,

A handwritten signature in black ink, appearing to be "Carlos Molina", written over a horizontal line.

Carlos Molina
Assistant Planner

Attachments:

- Decision Letter
- Property Survey
- Project Plans



City of Pomona

MINOR CERTIFICATE OF APPROPRIATENESS DECISION LETTER

FILE NO: **MINCOA 000178-2024**

A request for a Minor Certificate of Appropriateness to install a PV system on the roof of a structure contributing to the Hacienda Park Historic District.

ADDRESS: **490 Preciado St.**

APPLICANT: James Kercheval

PROJECT PLANNER: Carlos Molina, Assistant Planner

DECISION: Approved File No(s). MINCOA 000178-2024

BASIS FOR DECISION

Staff reviewed Pomona's Historic Preservation Ordinance (Section .5809-13), and the applicable design standards in Preserving Pomona – The Pomona Guide to Historic Preservation. In order to approve a Minor Certificate of Appropriateness Staff must determine that the findings contained in the City's Historic Preservation Ordinance can be made.

Applicable Design Standards

- There will be no change in appearance of the roof.
- The solar panels are removable so that, if removed at a later date, will not cause a change in the appearance of the roof;
- The solar panels are removable so that, if removed at a later date, will not cause the historic roofing material of the roof to be removed; and
- Any removal of roofing material at the time of installation will be replaced in-kind, causing no change in appearance and is subject to a reroof permit.
- Project meets City's preferred location for solar panels (Guide to Installing Solar Panels) (Not required under state law)
- Project Applicant or owner signed Conditions of Approval

CONDITIONS OF APPROVAL:

The Planning Division has completed its review of **MINCOA 000178-2024**. The request has been **approved**. The approval is subject to the following conditions:



City of Pomona

MINOR CERTIFICATE OF APPROPRIATENESS DECISION LETTER

1. The approval shall be used in the manner requested and shall be in substantial conformity with the plans approved by the Planning Division on the date listed on this letter, in accordance with the revision and/or additional conditions specifically required in this approval.
2. The approval shall be valid for not more than one year from the date of Permit approval. The Planning Division may grant a time extension for one (1) year provided that a written request by the applicant is submitted to the Planning Division within thirty (30) days prior to the expiration date without a fee. If plans are submitted to the Building and Safety division within one year from the date of approval, the proposed action shall be considered active.
3. The applicant shall obtain any required permits from the Building & Safety Division and/or Department of Public Works.
4. In the event that the approved plans under this Minor Certificate of Appropriateness are inconsistent with the provisions of the California Code of Regulations, Title 24 and/or any other applicable uniform building codes, the applicable building codes shall prevail.
5. Any deviation from the approved plans, shall require modification to the Certificate of Appropriateness and require approval of the Planning Division and, if necessary, the Historic Preservation Commission.
6. All project conditions shall be imprinted on the title sheet of the construction drawings (if required). The approved set of plans shall be retained on-site for review by Building Inspectors during the course of construction.
7. Prior to Occupancy the Planning Division shall inspect the premises to ensure the Conditions of Approval have been met and that the project has been constructed per the approved plans.
8. Construction Activities:

Hours of construction activity shall be limited to:

7:00 a.m. to 8:00 p.m., Monday through Saturday
(There shall be no construction allowed on Sunday or on any Federal or State Holiday)
9. Violation of any of the conditions of this permit shall be cause for revocation and termination of all rights thereunder.
10. The applicant shall obtain a building permit prior to any demolition or construction.
11. All ground and roof-mounted equipment is required to be fully screened from view. Upon final inspection, Planning Division staff may require additional screening if warranted, through either landscaping, walls or a combination thereof.



City of Pomona

MINOR CERTIFICATE OF APPROPRIATENESS DECISION LETTER

12. There will be **NO** change in appearance of the roof;
13. The solar panels will be installed in such a manner that they are removable at a later date **WITHOUT** affecting the historic character of the roof;
14. The solar panels will be installed in such a manner that they are removable at a later date **WITHOUT** having to remove the historic roof material.
15. Any removal of existing roof material at the time of installation will be replaced with a like material causing **NO** change in appearance and subject to a reroof permit.

APPEALS

This decision will become final on March 05, 2024, unless an appeal is filed with the Planning Division prior to this date. The applicant or any member of the public may file an appeal. There is no cost to file an appeal for a Minor Certificate of Appropriateness. Appeals may be filed with the contact listed in this letter.

Sincerely,

Geoffrey Starns, AICP, LEED AP BD+C
Historic Preservation Supervisor

February 12, 2024

Date

State of California - The Resources Agency
DEPARTMENT OF PARKS AND RECREATION
PRIMARY RECORD

Primary #
HRI #
Trinomial
NRHP Status Code

Other Listings
Review Code

Reviewer

Date

Page 223 of 277

*Resource Name or #: (Assigned by Recorder) 490 PRECIADO ST

P1. Other Identifier: _____

*P2. Location: Not for Publication

and (P2b and P2c or P2d. Attach a location map as necessary.)

*b. USGS 7.5' Quad _____ Date _____ T _____; R _____; 1/4 of _____ 1/4 of Sec _____; _____ B.M.

c. Address 490 PRECIADO ST City: Riverside Zip _____

d. UTM (Give more than one for large and/or linear resource Zone _____; _____ mE/ _____ mN

e. Other Locational Data: Contributing with modifications

*P3a. Description: (Describe resource and its major elements. Include design, materials, condition, alterations, size, setting, and boundaries)

This 1926 home is identifiable as a Tudor Revival by its steeply pitched roof, dominant cross-front-gable, and multiple groups of multi-paned windows. It is uncommon to see clapboard siding in a Tudor home, but not unheard of. The original owner was a manager at the local Kerckhoff-Cuzner Mill, and perhaps this accounts for the redwood siding of the home.

Windows are casement window, which is also typical of the style with eight panes each. The second story features french doors.

The second story balcony is cantilevered and covered by the principle roof.

Garage is attached and located at the back of the house.

Some windows have been replaced on the west side of the house with aluminum framed windows in the 1950s.

*P3b. Resource Attributes: (List attributes and codes) HP2

*P4. Resources Present: Building Structure Object Site District Element of District Other (isolates, etc.)

P5b. Description of Photo:
(View, date, accession #)

*P6. Date Constructed: 1926

Age and Sources: Historic

Prehistoric Both

*P7. Owner and Address:

Pomona CA

*P8. Recorded by: (name, affiliation, and address)

*P9. Date Recorded: _____


*P10. Survey Type: (Describe)

Other Activity

*P11. Report Citation: (Cite survey report and other sources, or enter "none.")

*Attachments: NONE Location Map Sketch Map Continuation Sheet Building, Structure, and Object Record
 Archaeological Record District Record Linear Reature Record Milling Station Record Rock Art Record
 Artifact Record Photograph Record Other (List) _____

SATELLITE & VICINITY PHOTOS



REVIEWED FOR CODE COMPLIANCE
 USING THE FOLLOWING CODES:
 2022 CALIFORNIA RESIDENTIAL CODE
 2022 CALIFORNIA BUILDING CODE
 2022 CALIFORNIA ELECTRICAL CODE
 2022 CALIFORNIA PLUMBING CODE
 2022 CALIFORNIA MECHANICAL CODE
 2022 CALIFORNIA ENERGY CODE
 2022 CALIFORNIA GREEN BUILDING STANDARDS CODE
 2022 CALIFORNIA FIRE CODE
 OTHER

REVIEWED FOR CODE COMPLIANCE
 CITY OF POMONA
 Building & Safety Division
 Permit # **C-055128-2023**

This issuance or granting of a permit based on approval of these plans shall not be construed to permit or approve any violation of the applicable codes or ordinance. No permit presumed to give authority to violate or cancel the provisions of such codes shall be valid.

Signature: **VS For Intervest**
 Approval Date: **9/1/2023**

CONDITIONS/REQUIREMENTS:
 Construction Waste Management
 Water Department Conditions
 Public Works Conditions
 Other

By: **Eric Corral** DATE: **01 September 2023**

COMPLETION OF THIS REVIEW DOES NOT AUTHORIZE CONSTRUCTION TO PROCEED IN VIOLATION OF ANY FEDERAL, STATE OR LOCAL REGULATIONS.

INTERVEST CONSULTING GROUP

490 Preciado St, Pomona, CA 91768, USA

Signed 5/08/2023
 Engineers Monument 1934

PLANNING DIVISION
 City of Pomona

JURISDICTION NOTES
 JURISDICTION: CITY OF POMONA
 UTILITY: SCE

INTERNATIONAL CODE REFERENCES AND COMPLIANCE:
 2022 CALIFORNIA GREEN BUILDING CODE
 2022 CALIFORNIA ENERGY CODE
 2022 CALIFORNIA PLUMBING CODE
 2022 CALIFORNIA MECHANICAL CODE
 2022 CALIFORNIA RESIDENTIAL CODE
 2022 CALIFORNIA FIRE CODE
 ALL OTHER CODES ADOPTED BY LOCAL LAW

ALL ELECTRICAL WORK SHALL BE PERFORMED BY A LICENSED ELECTRICIAN IN ACCORDANCE WITH THE 2022 LOS ANGELES COUNTY ELECTRICAL CODE, 2022 CALIFORNIA ELECTRICAL CODE, 2022 CALIFORNIA PLUMBING CODE, 2022 CALIFORNIA MECHANICAL CODE, 2022 CALIFORNIA RESIDENTIAL CODE, 2022 CALIFORNIA FIRE CODE, AND ANY APPLICABLE NATIONAL ELECTRICAL CODE. ALL ELECTRICAL WORK SHALL BE PERFORMED BY A LICENSED ELECTRICIAN IN ACCORDANCE WITH THE 2022 LOS ANGELES COUNTY ELECTRICAL CODE, 2022 CALIFORNIA ELECTRICAL CODE, 2022 CALIFORNIA PLUMBING CODE, 2022 CALIFORNIA MECHANICAL CODE, 2022 CALIFORNIA RESIDENTIAL CODE, 2022 CALIFORNIA FIRE CODE, AND ANY APPLICABLE NATIONAL ELECTRICAL CODE.

GENERAL INFO

OCCUPANCY: R3
 CONSTRUCTION: SINGLE-FAMILY RESIDENTIAL
 ZONING: 0 PSF
 GROUND SNOW LOAD: 95MPH
 WIND SPEED: C
 WIND EXPOSURE: 2
 NUMBER OF STORIES: 2

SCOPE OF WORK

INSTALLATION OF [N] 11.60 KW DC PV ARRAY

PV ONLY
 29 Q PEAK DUO BLK ML-G10-400W
 29 ENPHASE IQPLUS-72-2US (240W) (S1-SB)
 1 AC DISCONNECT(S)
 1 ENPHASE IQ COMBINER PANEL
 5 EZ SOLAR J-BOX

INDEX

PV1.0 COVER SHEET
 PV2.0 PROPERTY PLAN
 PV2.1 SITE PLAN
 PV2.2 RAFTER & ATTACHMENT PLAN
 PV3.0 ROOF ATTACHMENT DETAILS
 PV3.1 STRUCTURAL DETAILS
 PV4.0 LINE DIAGRAM
 PV4.1 ELECTRICAL CALCULATIONS
 PV5.0 LABELS
 PV5.1 PLACARD
 ATTACHED CUTSHEETS

INTERNATIONAL CODES

ALL WORK SHALL COMPLY WITH:
 1. 2021 INTERNATIONAL BUILDING CODE
 2. 2021 INTERNATIONAL RESIDENTIAL CODE
 3. 2020 NATIONAL ELECTRICAL CODE

CONTRACTORS LICENSE

PROJECT SOLAR
 License #: 1099181, C10
 Expiry Date: 11/30/2024
 JACOB MICHAEL WESTPHAL
Jacob Michael Westphal

REV BY COMMENTS
 REV - ARKIM F. -

<p>DESIGNED BY: ARKIM F. REVISION: - DATE: 4/13/2023</p>		<p>PAGE NAME: COVER SHEET SHEET: PV 1.0</p>
<p>PROJECT INFO</p> <p>11.60 KW DC PV ARRAY 8.41 KW AC PV ARRAY POMONA CA 91768</p>	<p>CUSTOMER INFO</p> <p>KRISTE WESTPHAL 490 PRECIADO ST POMONA CA 91768</p>	<p>JOB NUMBER: 5603816732 MOUNTING SYSTEM: IRONRIDGE, L-MOUNT MODULES: (29) Q PEAK DUO BLK ML-G10-400W INVERTER: (29) ENPHASE IQPLUS-72-2US (240W) (S1-SB)</p>





1/32" = 1'-0" SCALE



Signed 5/08/2023

PLANNING DIVISION



DIGITAL STAMP OF APPROVAL



License #: 1099181, C10
Expiry Date : 11/30/2024

JACOB MICHAEL WESTPHAL
Jacob Michael Westphal


REVIEWED
Sep 01, 2023
INTERWEST CONSULTING GROUP
COMPLETION OF THIS REVIEW DOES NOT CONSTITUTE A GUARANTEE OF ACCURACY OR A WARRANTY OF ANY KIND. THIS REVIEW IS LIMITED TO THE INFORMATION PROVIDED BY THE CLIENT AND DOES NOT CONSTITUTE A GUARANTEE OF ACCURACY OR A WARRANTY OF ANY KIND.

PROJECT SOLAR		JOB NUMBER 580816732		CUSTOMER INFO		PAGE NAME PLOT PLAN	
PROJECT SOLAR		ACCOUNTING SYSTEM IRONRIDGE, L/MOUNT		KRISTIE KERCHEVAL		DESIGNED BY ARKIM F.	
PROJECT SOLAR		MODULES (29) Q-PEAK D10 B.L.K ML-G10-400W		490 PRECIADO ST POMONA CA 91768		DATE 4/19/2023	
PROJECT SOLAR		INVERTER (29) EMPHASE (08PLUS-722-US (240V) (SI-S8)		CA 91768		REVISION =	
PROJECT SOLAR				11.60 KW DC PV ARRAY		SHEET PT/7.0	
PROJECT SOLAR				8.41 KW AC PV ARRAY			



1/16" = 1'-0" SCALE

FRONT OF RESIDENCE
490 PRECIADO ST



HEIGHT OF THE SYSTEM WILL NOT EXCEED THE BUILDING HEIGHT
ALL 3' FIRE SETBACKS ARE MEASURED INWARD FROM THE LOAD-BEARING WALL NOT FROM THE EDGE OF ANY EAVE OR OVERHANG.

- MP1 WITH 11 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S1-SB] PER MODULE
- MP2 WITH 4 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S1-SB] PER MODULE

LEGEND

- (M) UTILITY METER
- AC DISCONNECT
- DC/AC MICROINVERTER
- (G) COMBINER PANEL
- (SUB) SUB PANEL
- (MSP) MAIN SERVICE PANEL
- (M) DEDICATED PV METER
- (J-BOX) JUNCTION BOX
- (Z) SETBACK



Signed 5/08/2023



THE HOUSE IS LOCATED ON A CORNER STREET



JOB NUMBER 5803816732	MOUNTING SYSTEM IRONRIDGE L-MOUNT	MODULES (29) Q-PEAK DUO BLK ML-G10-400W	INVERTER (29) ENPHASE IQ8PLUS-72-2-US (240V) [S1-SB]	PV SYSTEM INFO 11.60 kWDC PV ARRAY &.41 kW AC PV ARRAY	CUSTOMER INFO KRISTIE KERCHEVAL 490 PRECIADO ST POMONA CA 91768	DESIGNED BY ARKIM F.	PAGE NAME SITE PLAN
						REVISION =	SHEET PV.Z1T




STRUCTURAL INFO	
FRAMING	: CONVENTIONAL
RAFTER SIZE	: 2X4
RAFTER SPACING	: 24
ROOF AREA	
TOTAL ARRAY AREA (SQFT)	: 612.5
TOTAL ROOF AREA (SQFT)	: 2655
AREA OF MODULES/TOTAL	: 23.07
NUMBER OF ATTACHMENTS	
105	
ROOF INFORMATION	
MP 1 AZIMUTH 183 PITCH 12.0/12	COMP SHINGLE
MP 2 AZIMUTH 183 PITCH 2.1/12	COMP SHINGLE
MP 3 AZIMUTH 93 PITCH 12.0/12	COMP SHINGLE
MP 4 AZIMUTH 183 PITCH 6.1/12	COMP SHINGLE
MP 5 AZIMUTH 273 PITCH 9.0/12	COMP SHINGLE



PROJECT SOLAR
 License #: 1099181, C10
 Expiry Date: 11/30/2024
Jacob Michael Westphal

DESIGNED BY	ARKIM F.	PAGE NAME	INSTALLATION
REVISION	---	DATE	4/13/2023
		SHEET	PTZZ



REVIEWED
 Sep 01, 2023
INTEREST CONSULTING GROUP
COMPLETION OF THIS DRAWING DOES NOT CONSTITUTE AN ENDORSEMENT OR GUARANTEE BY INTEREST CONSULTING GROUP OF ANY FEDERAL, STATE OR LOCAL REGULATIONS.

PROJECT INFO	CUSTOMER INFO
11.60 KW DC PV ARRAY	KRISTIE KERCHEVAL
8.41 KW AC PV ARRAY	490 PRECIADO ST
	POMONA
	CA 91768

PROJECT SOLAR

1/16" = 1'-0" SCALE

FRONT OF RESIDENCE

490 PRECIADO ST

DRIVEWAY

DETACHED STRUCTURE

UTILITY METER MAIN SERVICE PANEL

ENPHASE IQ COMBINER AC DISCONNECT SUB PANEL

MP4 WITH 2 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB] PER MODULE




MP5 WITH 2 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB] PER MODULE

MP3 WITH 10 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB] PER MODULE

MP1 WITH 11 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB] PER MODULE



MP2 WITH 4 MODULES (1) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB] PER MODULE

JOB NUMBER	580816732
OUNTING SYSTEM	IRONRIDGE, L-MOUNT
MODULES	(29) Q-PEAK DUO BLK ML-610-40W
INVERTER	(29) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB]



DETAIL, SPLICE, XRD

ITEM NO.	DESCRIPTION	QTY.
1	FLASHING, ROUNDED CORNERS, 9" X 12" X .040", .438" HOLE, 5052, MILL	1
2	L-FOOT, 7" X 3.30" FOR .3875" THICKNESS, 2-1/16" SLOT, 6061-T686069A-161, MILL	1
3	WASHER, SEALING, 5/16" ID X 3/4" OD, EPDM BONDED SS	1
4	LAG SCREW, HEX HEAD, 5/16" x 4", 18-8 SS	1
5	STRUCTURAL SCREW, OMPV, T-30 HEX WASHER HEAD, 5/16" X 4-1/2", 18-8SS	1



TITLE: QMLM 8 QMLM-ST L-MOUNT, 2-1/16" SLOT

UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES FRACTIONAL: 1/16" DECIMAL: .01" TYPICAL: .005" SCALE: 1:1

SIZE: A DATE: 7/16/2018



DESIGNED BY: RAD REV: 9

DATE: 7/16/2018

SCALE: 1:1

PROJECT: 5803916732 SHEET 1 OF 1

BOLT BONDING 3 8-16 HEAD



Signed 5/08/2023

PROJECT SOLAR
License #: 1099181, C10
Expiry Date: 11/30/2024
JACOB MICHAEL WESTPHAL
Jacob Michael Westphal

PROJECT SOLAR

JOB NUMBER: 5803916732
MOUNTING SYSTEM: IRONRIDGE L-MOUNT
MODULES: (29) Q-PEAK DUO BLK ML-G10 400W
INVERTER: (29) ENPHASE Q-PLUS-72-2-US (240V) (S1-SB)

DESIGNED BY: ARMM F.
REVISION: --
DATE: 4/13/2023

PAGE NAME: TRACKING SHEET PV3.0

PV SYSTEM INFO: 11.60 KW DC PV ARRAY, 8.41 KW AC PV ARRAY
CUSTOMER INFO: KRISTE KERCHEVAL, 480 PRECADO ST, POKONA, CA 91788

PLANNING DIVISION: CITY OF TIMONIA, MISSOURI

ELECTRICAL NOTES

1. ENPHASE IQ8 SERIES MICROINVERTERS DO NOT REQUIRE GROUNDING ELECTRODE CONDUCTORS OR EQUIPMENT GROUNDING CONDUCTORS. THE MICROINVERTERS ITSELF HAS CLASS II DOUBLE-INSULATED RATING, WHICH INCLUDES GROUND FAULT PROTECTION.
2. ENPHASE Q CABLE HAS NO NEUTRAL WIRE - (2) WIRE DOUBLE INSULATED CABLING - RAILS ARE BONDED WITH UL 2703 RATED LAY-IN LUGS
3. BARE COPPER IS TRANSITIONED TO THINWALL-W VIA IRREVERSIBLE CRIMP, GEC TO BE CONTINUOUS PER CEC 250.64(C)
4. ENPHASE IQ ENVOY INSIDE IQ COMBINER REQUIRES A NEUTRAL TO BE LANDED AT THE NEUTRAL BUSS AT MAIN PANEL PER ENPHASE INSTALLATION INSTRUCTIONS.
5. ENPHASE MICROINVERTERS ARE ALL RAPID SHUTDOWN READY PER NEC 690.12
6. DISCONNECT SHALL BE INSTALLED WITHIN 10FT OF BI-DIRECTIONAL UTILITY METER, OR BE PROPERLY LABELED WITH DIRECTIONAL MAPPING.
7. INVERTER SHALL BE CERTIFIED UNDER UL1741.
8. 24/7 UNESCORTED KEYLESS ACCESS SHALL BE PROVIDED TO UTILITY EQUIPMENT.
9. THERE ARE 1 UTILITIES TO THE PROPERTY BUT NOT OVER THE ROOF.
10. THIS SYSTEM IS GRID-INTERTIED VIA A UL-LISTED POWER-CONDITIONING INVERTER.
11. A NATIONALLY - RECOGNIZED TESTING LABORATORY SHALL LIST ALL EQUIPMENT IN COMPLIANCE WITH ART. 110.3.
12. WHERE ALL TERMINALS OF THE DISCONNECTING MEANS MAY BE ENERGIZED IN THE OPEN POSITION, A SIGN WILL BE PROVIDED WARNING OF THE HAZARDS PER ART. 690.12(B)
13. CIRCUITS OVER 250V TO GROUND SHALL COMPLY WITH ART. 250.97, 250.92(B).
14. ALL WIRES SHALL BE PROVIDED WITH STRAIN RELIEF AT ALL ENTRY INTO BOXES AS REQUIRED BY UL LISTING.
15. MODULE FRAMES SHALL BE GROUNDED AT THE UL - LISTED LOCATION PROVIDED BY THE MANUFACTURER USING UL LISTED GROUNDING HARDWARE.
16. MODULE FRAMES, RAIL, AND POSTS SHALL BE BONDED WITH EQUIPMENT GROUND CONDUCTORS.

SYSTEM CALCULATIONS

MODULE OPERATING CURRENT = 11.14 A
 INVERTER MAX INPUT CURRENT = 15 A
 11.14 A < 15 A, OK
 MODULE OPERATING VOLTAGE = 38.09 V
 INVERTER INPUT OPERATING VOLTAGE RANGE = 16 V - 60 V
 16 V < 38.09 V < 60 V, OK
 MODULE Voc = 45.55 V
 VOLTAGE CORRECTION FACTOR = 1.14
 45.55 V (1.14) = 51.93 V
 INVERTER MAX INPUT VOLTAGE = 60 V
 51.93 V < 60 V, OK
 MODULE ISC = 11.14 A

NUMBER OF MICROINVERTERS IN CIRCUIT #1 = 10 INVERTER MAX OUTPUT CURRENT = 1.21 A
 10(1.21 A) (1.25) = 15.125 A, USE 20 A BREAKER
 NUMBER OF MICROINVERTERS IN CIRCUIT #2 = 10 INVERTER MAX OUTPUT CURRENT = 1.21 A
 10(1.21 A) (1.25) = 15.125 A, USE 20 A BREAKER
 NUMBER OF MICROINVERTERS IN CIRCUIT #3 = 9 INVERTER MAX OUTPUT CURRENT = 1.21 A
 9(1.21 A) (1.25) = 13.6125 A, USE 20 A BREAKER

INVERTER SPECIFICATIONS

MANUFACTURER/MODEL #	ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB1]
MIN/MAX DC VOLT RATING	25-58V
MAX INPUT POWER	235W-440W
NOMINAL AC VOLTAGE RATING	240/211-264V
MAX AC CURRENT	1.21A
MAX MODULES PER CIRCUIT	10 (SINGLE PHASE)
MAX OUTPUT POWER	280 VA
SOLAR MODULE SPECIFICATION	
MANUFACTURER/MODEL #	Q.PEAK DUO BLK ML-G10 400W
VMP	38.09 V
IMP	10.45 A
VOC	45.55 V
ISC	11.14 A
TEMP. COEFF. VOC	-0.27%/K
MODULE DIMENSION	74in x 41.1in x 1.26in

TOTAL SOLAR BACKFEED
 TOTAL INVERTERS = 29
 29 X 1.21 X 1.25 = 43.86 A; BREAKER USED: 50A

MAX SYSTEM VOLTAGE
 Max String Length :10
 Max Voltage (V) :240 V

UTILITY METER



MSP DEADPLATE OFF



SUBPANEL DEADPLATE OFF



REVIEWED
 See 01, 2023
 WEST CONSULTING GROUP



PROJECT SOLAR
 License #: 1099181, C10
 Expiry Date: 11/30/2024
JACOB MICHAEL WESTPHAL
Jacob Michael Westphal

JOB NUMBER	68081672	CUSTOMER INFO	KRISTE KERCHEVAL
Mounting SYSTEM	IRONRIDGE, L-MOUNT	11.68 KW DC PV ARRAY	490 PIEDRADO ST
MODULES	(29) QPEAK DUO BLK ML-G10-400W	8.41 KW AC PV ARRAY	POMONA
INVERTER	(29) ENPHASE IQ8PLUS-72-2-US (240V) [S11-SB1]	CA 91768	CA 91768

DESIGNED BY
 ARKMF.
 REVISION
 DATE
 4/13/2023

PAGE NAME
 ELECTRICAL
 CALCS
 SHEET
 PV 4.1



MAIN PHOTOVOLTAIC SYSTEM DISCONNECT

NEC 690.13(B) Each PV system disconnecting means shall plainly indicate whether it is the open (off) or closed (on) position and be permanently marked, "PV SYSTEM DISCONNECT" or equivalent.

WARNING
ELECTRIC SHOCK HAZARD
TERMINALS ON THE LINE AND
LOAD SIDES MAY BE ENERGIZED
IN THE OPEN POSITION.

690.13(B) & 690.15(C) Where all terminals of the disconnecting means may be energized in the open position, a warning sign shall be mounted on or adjacent to the disconnecting means.

WARNING
NEVER TURN OFF THE MAIN DISCONNECTING MEANS ON THE LOAD SIDE OF THE PHOTOVOLTAIC SYSTEM.

705.12 (B)(3)(2) An open-circuit warning label shall be applied to the distribution equipment adjacent to the back-fed breaker from the inverter. (.)

WARNING
THIS EQUIPMENT IS A PHOTOVOLTAIC SYSTEM. IT CONTAINS LIVE ELECTRICAL CIRCUITS. NEVER TOUCH THE EQUIPMENT OR THE WIRING. ALWAYS USE THE PROPER SAFETY PROCEDURES FOR PHOTOVOLTAIC SYSTEMS.

705.12 (B)(3)(3) (Permanent warning labels shall be applied to distribution equipment)


PHOTOVOLTAIC AC DISCONNECT

Maximum AC Output Current: 43.88 A
Maximum Open-Circuit Voltage: 240V

NEC 690.54(All) Interactive system(s) points of interconnection with other sources shall be marked at an accessible location at the inverter with a sign that reads "PHOTOVOLTAIC AC DISCONNECT" or equivalent, and the nominal operating ac voltage. (.)

PHOTOVOLTAIC AC DISCONNECT

NEC 690.13(B) Each PV system disconnecting means shall plainly indicate whether it is the open (off) or closed (on) position and be permanently marked, "PV SYSTEM DISCONNECT" or equivalent.



SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN



690.59 (C) Buildings with PV systems shall have a permanent label on the PV system indicating that the system is equipped with PV systems are considered or at an approved readily visible location and shall indicate the location of rapid shutdown initiation devices. The label shall include a simple diagram of a house with a solar array and a label on the array that reads "SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN" shall utilize capitalized characters with a minimum height of 3/8 in. in black on yellow background, and shall be placed at a minimum height of 3/16 in. in black on white background. (.)

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

690.59 (C)(1) A rapid shutdown switch shall have a label located on or no more than 3 ft. from the switch that indicates the working. The label shall be reflective, with all letters capitalized and having a minimum height of 3/8 in., in white on red background. (.)

DO NOT UPSIZE MAIN BREAKER HAS BEEN DOWN-SIZED FOR PV SOLAR SYSTEM CONNECTION



PROJECT SOLAR
License #: 1099181, C10
Expiry Date: 11/30/2024
JACOB MICHAEL WESTPHAL
Jacob Michael Westphal

REVIEWED
Sep 01, 2023
INTERWEST CONSULTING GROUP
COMPLETION OF THIS REVIEW DOES NOT AUTOMATICALLY CONSTITUTE AN ENDORSEMENT OR A GUARANTEE OF THE QUALITY OF THE DESIGN OR CONSTRUCTION OF THE PROJECT OR THE QUALITY OF THE DESIGN OR CONSTRUCTION OF THE PROJECT.


JOB NUMBER	5803916732	CUSTOMER INFO	KRISTIE KEROCHEVAL	DESIGNED BY	ARKINF.	PAGE NAME	LABELS
	IRONRIDGE L-MOUNT		490 PRECADO ST	REVISION	---	SHEET	PV 5.0
MOUNTING SYSTEM	IRONRIDGE L-MOUNT	POWORA	CA 91768	DATE	4/13/2023		
MODULES	(29) Q-PEAK DUO BLK ML-G10-400W						
INVERTER	(29) ENPHASE IQ8P-US-72-3-US (240V) [S1-S8]						
PV SYSTEM INFO		11.00 KW DC PV ARRAY		8.41 KW AC PV ARRAY			

PROJECT SOLAR

NEC 690.54

(A permanent plaque or directory shall be installed at each service equipment location, or at an approved readily visible location. The plaque or directory shall denote the location of each power source disconnecting means for the building or structure and be grouped with other plaques or directories for other on-site sources. The plaque or directory shall be marked with the wording "CAUTION: MULTIPLE SOURCES OF POWER." Any posted diagrams shall be correctly oriented with respect to the diagram's location. The marking shall comply with 110.21(B).)

CAUTION
 MULTIPLE SOURCES OF POWER
 WITH AC DISCONNECTS LOCATED AS SHOWN



PLACARD
 10F1



PROJECT SOLAR
 License #: 1099181, CIO
 Expiry Date : 11/30/2024
JACOB MICHAEL WESTPHAL
Jacob Michael Westphal

REVIEWED
 Sep 01, 2023
INTERWEST CONSULTING GROUP
COMPLETION OF THIS REVIEW DOES NOT AUTOMATICALLY CONSTITUTE AN APPROVAL TO PROCEED IN ACCORDANCE WITH THE STATE AND LOCAL REGULATIONS.

	JOB NUMBER: 5903876732 MOUNTING SYSTEM: ROUNDOSE, L-MOUNT MODULES: (29) Q1 PEAK DUO BLK ML-G10 400W INVERTER: (29) ENPHASE (C) PLUS-72-2-US (240V) (S1-5B)	PV SYSTEM INFO: 11.60 KW DC PV ARRAY 8.41 KW AC PV ARRAY	CUSTOMER INFO: KRISTIE KERCHEVAL 400 PRECADO ST POMONA CA 91768	DESIGNED BY: ARKMF. REVISION: - DATE: 4/13/2023	PAGE NAME: PLACARD SHEET: PV 5.1
	DESIGNER'S SEAL AND SIGNATURE				



Q. PEAK DUO BLK ML-G10+

385-405

ENDURING HIGH PERFORMANCE



BREAKING THE 20% EFFICIENCY BARRIER
Q. ANTUM DUO Z technology with zero gap cell layout boosts module efficiency up to 20.9%.

THE MOST THOROUGH TESTING PROGRAMME IN THE INDUSTRY
Q. CELLS is the first solar module manufacturer to pass the most comprehensive quality programme in the industry. The new "Quality Controlled PV" of the independent certification institute TÜV Rheinland.

INNOVATIVE ALL-WEATHER TECHNOLOGY
Optimal yields, whatever the weather with excellent low-light and temperature behavior.

ENDURING HIGH PERFORMANCE
Long-term yield security with Anti PID Technology, Anti PID Technology, Hot-Spot Protect and Traceable Quality Tru.Q™

EXTREME WEATHER RATING
High-tech aluminum alloy frame, certified for high snow (5400Pa) and wind loads (4000Pa).

A RELIABLE INVESTMENT
Inclusive 25-year product warranty and 25-year linear performance warranty*.

* A1: Test conditions according to IEC/TS 62504-2:2015, method A1-c (500V, 90h)
* See data sheet on rear for further information.




THE IDEAL SOLUTION FOR:
Residential arrays on residential buildings

Engineered in Germany


MECHANICAL SPECIFICATION

Format	74.0in x 41.1in x 1.26in (including frame) (1879mm x 1045mm x 32mm)
Weight	48.5lb (22.0kg)
Front Cover	0.13in (3.2mm) thermally pre-embossed glass with anti-reflection technology
Back Cover	Composite film
Cell	Black monocrystalline Q. ANTUM solar half cells
Cell	6 x 212 monocrystalline Q. ANTUM solar half cells
Junction Box	2.09-3.98in x 1.26-2.38in x 0.58-0.71in (53-101mm x 32-60mm x 15-18mm), IP67, with bypass diodes
Cable	4mm² Solar cable, (4) x 46.2in (1250mm), (2) x 48.2in (1250mm)
Connector	Shubli MC4; IP68



ELECTRICAL CHARACTERISTICS

POWER CLASS	385	390	395	400	405
MINIMUM PERFORMANCE AT STANDARD TEST CONDITIONS, STC (POWER TOLERANCE ±5W/-0V)					
Power at MPP	385	390	395	400	405
Short Circuit Current ¹	I _{sc} [A]	11.04	11.07	11.10	11.14
Open Circuit Voltage ¹	V _{oc} [V]	45.19	45.23	45.27	45.30
Current at MPP	I _{mpp} [A]	10.59	10.65	10.71	10.77
Voltage at MPP	V _{mpp} [V]	36.36	36.62	36.88	37.13
Efficiency ¹	η [%]	≥19.6	≥19.9	≥20.1	≥20.6
MINIMUM PERFORMANCE AT NORMAL OPERATING CONDITIONS, NMOT:					
Power at MPP	P _{mp} [W]	289.8	292.8	295.3	300.1
Short Circuit Current	I _{sc} [A]	8.80	8.82	8.85	8.87
Open Circuit Voltage	V _{oc} [V]	42.62	42.65	42.69	42.72
Current at MPP	I _{mpp} [A]	8.95	8.91	8.93	8.91
Voltage at MPP	V _{mpp} [V]	34.59	34.81	35.03	35.25
<small>Minimum performance based on P_{mp} ±0.3%, I_{sc} ±0.5%, V_{oc} ±0.2%, AMI 1.5 according to IEC 60904-2:2006, NMOT, IEC 61851-1:2015</small>					
Q CELLS PERFORMANCE WARRANTY					
At least 98% of nominal power during first year. Thereafter max. 0.5% degradation per year. At least 83.5% of nominal power up to 25 years.					
All data within measurement tolerance. Full warranties in accordance with local laws and regulations of the respective country.					



Typical module performance under test conditions in comparison to STC conditions (25°C, 1000W/m²)

TEMPERATURE COEFFICIENTS

Temperature Coefficient of I _{sc}	α [1/K]	+0.04	Temperature Coefficient of V _{oc}	β [mV/K]	-0.27
Temperature Coefficient of P _{mp}	γ [1/K]	-0.24	Nominal Module Operating Temperature	NMOT [°F]	109 ± 5.4 (43 ± 3 °C)

PROPERTIES FOR SYSTEM DESIGN

Maximum System Voltage V _{sys}	[V]	1000 (IEC) / 1000 (UL)	PV module classification
Maximum Series Fuse Rating [A DC]	[A DC]	20	Fuse Rating based on ANSI/UL 61730
Max. Design Load, Push/Pull [Bar/ft²]	[Bar/ft²]	75 (5600Pa) / 55 (2900Pa)	Permitted Module Temperature on Continuous Duty
Max. Test Load, Push/Pull [Bar/ft²]	[Bar/ft²]	113 (8400Pa) / 84 (4000Pa)	

QUALIFICATIONS AND CERTIFICATE REVIEWED

SEP 01, 2023



Q. CELLS is a member of the Q CELLS Group.

Note: Installation instructions must be followed. See the installation and operating manual or contact our technical service department for further information on approved installation and use of this product.

Q CELLS America Inc.
400 Spectrum Center Drive, Suite 1400, Irvine, CA 92618, U.S.A. | TEL: +1-949-749-9886 | EMAIL: inquiry@q-cells.com | WEB: www.q-cells.us



Engineered in Germany



IQ8 Series Microinverters

Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built in advanced 55nm technology with high-speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrates with the Enphase IQ Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included O-DCC-2 saddle wire and plug-n-play MCI connectors, as detailed according to manufacturer's instructions.

© 2022 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ8 Microinverters, and other names are trademarks of Enphase Energy, Inc. Data subject to change.

IQ8SE-08-0001-01-EN-US-2022-03-17

- Easy to install**
- Lightweight and compact with plug-n-play connectors
 - Power Line Communication (PLC) between components
 - Faster installation with simple two-wire cabling

- High productivity and reliability**
- Produce power even when the grid is down*
 - More than one million cumulative hours of testing
 - Class II double-insulated enclosure
 - Optimized for the latest high-powered PV modules

- Microgrid-forming**
- Complies with the latest advanced grid support**
 - Remote automatic updates for the latest grid requirements
 - Configurable to support a wide range of grid profiles
 - Meets CA Rule 21 (UL 1741-SA) requirements

* Only when installed with IQ System Controller 2, meets UL 1741, IQ8H-200V operates only in grid-tied mode.
** IQ8 Series Microinverters supports split phase, 240V, IQ8H-208 supports split phase, 208V only.

IQ8 Series Microinverters

Commonly used module pairings*	W 235 - 350	235 - 440	280 - 480	280 - 500	320 - 540	295 - 500*
Module compatibility	60-cell/720 half-cell	60-cell/720 half-cell	60-cell/720 half-cell	66-cell/732 half-cell and 72-cell/144 half-cell	66-cell/732 half-cell and 72-cell/144 half-cell	66-cell/732 half-cell and 72-cell/144 half-cell
MPP1 voltage range	V 27 - 37	29 - 45	33 - 45	36 - 45	38 - 45	36 - 45
Operating range	V 25 - 48		25 - 58			
Min/max start voltage	V 30 / 48		30 / 58			
Max DC current† (module bc)	A 80		80			
Overvoltage class DC port	A II		II			
DC port backfeed current	mA 0		0			
PV array configuration	1x1 (grounded array); No additional DC side protection required; AC side protection requires max 20A per branch circuit					

Peak output power	W 245	300	330	366	384	366
Max continuous output power <td>W 240</td> <td>280</td> <td>325</td> <td>348</td> <td>380</td> <td>366</td>	W 240	280	325	348	380	366
Nominal (L-L) voltage/range† <td>V 240 / 211 - 264</td> <td></td> <td>240 / 211 - 264</td> <td></td> <td>208 / 183 - 260</td> <td></td>	V 240 / 211 - 264		240 / 211 - 264		208 / 183 - 260	
Max continuous output current <td>A 1.0</td> <td>1.21</td> <td>1.35</td> <td>1.45</td> <td>1.58</td> <td>1.73</td>	A 1.0	1.21	1.35	1.45	1.58	1.73
Nominal frequency <td>Hz 60</td> <td></td> <td>60</td> <td></td> <td></td> <td></td>	Hz 60		60			
Extended frequency range <td>Hz 50 - 68</td> <td></td> <td>50 - 68</td> <td></td> <td></td> <td></td>	Hz 50 - 68		50 - 68			
AC short circuit fault current over 3 cycles <td>A rms 2</td> <td></td> <td>2</td> <td></td> <td></td> <td></td>	A rms 2		2			
Max units per 20 A (L-L) branch circuit† <td>16</td> <td>13</td> <td>11</td> <td>11</td> <td>10</td> <td>9</td>	16	13	11	11	10	9
Total harmonic distortion <td>% <5%</td> <td></td> <td>III</td> <td></td> <td></td> <td></td>	% <5%		III			
Overvoltage class AC port <td>mA III</td> <td></td> <td>III</td> <td></td> <td></td> <td></td>	mA III		III			
AC port backfeed current <td>mA 0</td> <td></td> <td>0</td> <td></td> <td></td> <td></td>	mA 0		0			
Power factor setting <td>Grid-tied power factor (adjustable)</td> <td>0.85 leading - 0.85 lagging</td> <td></td> <td></td> <td></td> <td></td>	Grid-tied power factor (adjustable)	0.85 leading - 0.85 lagging				
Peak efficiency <td>% 97.5</td> <td>97.8</td> <td>97.8</td> <td>97.8</td> <td>97.8</td> <td>97.4</td>	% 97.5	97.8	97.8	97.8	97.8	97.4
CEC weighted efficiency <td>% 97</td> <td>97</td> <td>97</td> <td>97.5</td> <td>97</td> <td>97</td>	% 97	97	97	97.5	97	97
Light-time power consumption <td>mW 60</td> <td></td> <td>60</td> <td></td> <td></td> <td></td>	mW 60		60			

Ambient temperature range -40°C to +60°C (-40°F to +140°F)
 Relative humidity range 4% to 100% (condensing)
 DC Connector type MCI
 Dimensions (HxWxD) 212 mm (8.37") x 175 mm (6.87") x 30.2 mm (1.2")
 Weight 1.08 kg (2.38 lbs)
 Cooling Natural convection - no fans
 Approved for wet locations Yes
 Pollution degree 3
 Enclosure NEMA Type 1 / outdoor
 Emission category / UV exposure rating Class II double-insulated, corrosion resistant polymer enclosure
 Certifications Class II double-insulated, corrosion resistant polymer enclosure

REVIEWED
 Sep 01, 2023
 The product is UL Listed as PV Rapid Shut Down Equipment and conforms with NEC 2014, NEC 2017, and UL 1741, UL 1741-SA, UL 1741-CD, UL 1741-CD1, UL 1741-CD2, UL 1741-CD3, UL 1741-CD4, UL 1741-CD5, UL 1741-CD6, UL 1741-CD7, UL 1741-CD8, UL 1741-CD9, UL 1741-CD10, UL 1741-CD11, UL 1741-CD12, UL 1741-CD13, UL 1741-CD14, UL 1741-CD15, UL 1741-CD16, UL 1741-CD17, UL 1741-CD18, UL 1741-CD19, UL 1741-CD20, UL 1741-CD21, UL 1741-CD22, UL 1741-CD23, UL 1741-CD24, UL 1741-CD25, UL 1741-CD26, UL 1741-CD27, UL 1741-CD28, UL 1741-CD29, UL 1741-CD30, UL 1741-CD31, UL 1741-CD32, UL 1741-CD33, UL 1741-CD34, UL 1741-CD35, UL 1741-CD36, UL 1741-CD37, UL 1741-CD38, UL 1741-CD39, UL 1741-CD40, UL 1741-CD41, UL 1741-CD42, UL 1741-CD43, UL 1741-CD44, UL 1741-CD45, UL 1741-CD46, UL 1741-CD47, UL 1741-CD48, UL 1741-CD49, UL 1741-CD50, UL 1741-CD51, UL 1741-CD52, UL 1741-CD53, UL 1741-CD54, UL 1741-CD55, UL 1741-CD56, UL 1741-CD57, UL 1741-CD58, UL 1741-CD59, UL 1741-CD60, UL 1741-CD61, UL 1741-CD62, UL 1741-CD63, UL 1741-CD64, UL 1741-CD65, UL 1741-CD66, UL 1741-CD67, UL 1741-CD68, UL 1741-CD69, UL 1741-CD70, UL 1741-CD71, UL 1741-CD72, UL 1741-CD73, UL 1741-CD74, UL 1741-CD75, UL 1741-CD76, UL 1741-CD77, UL 1741-CD78, UL 1741-CD79, UL 1741-CD80, UL 1741-CD81, UL 1741-CD82, UL 1741-CD83, UL 1741-CD84, UL 1741-CD85, UL 1741-CD86, UL 1741-CD87, UL 1741-CD88, UL 1741-CD89, UL 1741-CD90, UL 1741-CD91, UL 1741-CD92, UL 1741-CD93, UL 1741-CD94, UL 1741-CD95, UL 1741-CD96, UL 1741-CD97, UL 1741-CD98, UL 1741-CD99, UL 1741-CD100.

UL LISTED
 The product is UL Listed as PV Rapid Shut Down Equipment and conforms with NEC 2014, NEC 2017, and UL 1741, UL 1741-SA, UL 1741-CD, UL 1741-CD1, UL 1741-CD2, UL 1741-CD3, UL 1741-CD4, UL 1741-CD5, UL 1741-CD6, UL 1741-CD7, UL 1741-CD8, UL 1741-CD9, UL 1741-CD10, UL 1741-CD11, UL 1741-CD12, UL 1741-CD13, UL 1741-CD14, UL 1741-CD15, UL 1741-CD16, UL 1741-CD17, UL 1741-CD18, UL 1741-CD19, UL 1741-CD20, UL 1741-CD21, UL 1741-CD22, UL 1741-CD23, UL 1741-CD24, UL 1741-CD25, UL 1741-CD26, UL 1741-CD27, UL 1741-CD28, UL 1741-CD29, UL 1741-CD30, UL 1741-CD31, UL 1741-CD32, UL 1741-CD33, UL 1741-CD34, UL 1741-CD35, UL 1741-CD36, UL 1741-CD37, UL 1741-CD38, UL 1741-CD39, UL 1741-CD40, UL 1741-CD41, UL 1741-CD42, UL 1741-CD43, UL 1741-CD44, UL 1741-CD45, UL 1741-CD46, UL 1741-CD47, UL 1741-CD48, UL 1741-CD49, UL 1741-CD50, UL 1741-CD51, UL 1741-CD52, UL 1741-CD53, UL 1741-CD54, UL 1741-CD55, UL 1741-CD56, UL 1741-CD57, UL 1741-CD58, UL 1741-CD59, UL 1741-CD60, UL 1741-CD61, UL 1741-CD62, UL 1741-CD63, UL 1741-CD64, UL 1741-CD65, UL 1741-CD66, UL 1741-CD67, UL 1741-CD68, UL 1741-CD69, UL 1741-CD70, UL 1741-CD71, UL 1741-CD72, UL 1741-CD73, UL 1741-CD74, UL 1741-CD75, UL 1741-CD76, UL 1741-CD77, UL 1741-CD78, UL 1741-CD79, UL 1741-CD80, UL 1741-CD81, UL 1741-CD82, UL 1741-CD83, UL 1741-CD84, UL 1741-CD85, UL 1741-CD86, UL 1741-CD87, UL 1741-CD88, UL 1741-CD89, UL 1741-CD90, UL 1741-CD91, UL 1741-CD92, UL 1741-CD93, UL 1741-CD94, UL 1741-CD95, UL 1741-CD96, UL 1741-CD97, UL 1741-CD98, UL 1741-CD99, UL 1741-CD100.

PLANNING DIVISION
 SMALL SCALE APPROVAL
 IQ8SE-08-0001-01-EN-US-2022-03-17



Tech Brief

QuickMount™ L-Mount®

Roof Protection without Compromise


The L-Mount® attachment, featuring an open-slotted L-Foot, is designed for cost-effective, single-bolt installation onto existing composition (asphalt) shingle roofs. The patented Elevated Water Seal Technology® has been integrated into the open-slotted L-Foot and flashing for fast installation, to provide maximum waterproofing.

To maximize versatility, the mount is available with a lag bolt or structural screw option for the strength you depend on. Both hardware options come with an installed EPDM bonded washer to seal and prevent water entry.


L-Mount features a 9x12" aluminum flashing with alignment guides and rounded corners, to easily slide under shingles and speed up installation on the roof. The kit is available in both mill and black finishes.



This component is part of the QuickMount® product line.



Elevated Water Seal Technology®
This proprietary flashing design cleverly places the roof penetration seal into an aluminum flange fused into the flashing, above the bolt hole. The secondary EPDM rubber seal keeps water out—raised above the path of rain water and out of harm's way.



Open-Slotted L-Foot
The redesigned L-Foot can rotate 360 degrees for easy installation. The open-slotted design allows the rail hardware to quickly drop-in and be compatible with any side-mounted racking on the market.



Pre-Installed Sealing Washer
Hardware options include a lag bolt or structural screw. The EPDM washer arrives already attached.



25-Year Warranty
Product guaranteed free of impairing defects.

Tech Brief

L-Mount® Installation Instructions


Installation Tools Required: tape measure, roofing bar, chalk line, stud finder, caulking gun, sealant compatible with roofing materials, drill with 7/32" or 1/8" bit, drill or impact gun with 1/2" socket.



Locate, choose, and mark centers of rafters to be mounted. Select the courses of shingles where mounts will be placed.



2 Carefully fit competition roof shingle with roofing bar just above placement of mount. Remove nails as required and backfill holes with approved sealant. See "Proper Flashing Placement" on next page.



3 Insert flashing between 1st and 2nd courses. Slide up so top edge of flashing is at least 1/2" higher than the butt-edge of the 2nd course and lower flashing edge is above the butt-edge of 1st course. Mark center for drilling.



4 If attaching with lag-bolt, use a 3/8" bit (Lag). Use a 1/2" bit (S1) for attaching with the structural screw. Drill pilot hole into roof and rafter, taking care to follow the rafter's grain. Drill into rafter as a drill guide. Drill a 2" deep hole into rafter.



5 Clean off any sawdust, and fill hole with sealant compatible with roofing materials.



6 Place L-Foot onto elevated flange and rotate L-Foot to desired orientation.



7 Tighten structural screw with a 3/8" hex key. Do not over-tighten. All the flange of the rafter must be covered. NOTE: The screw can no longer easily rotate. DO NOT over-tighten. NOTE: Structural screw can be driven with T-bits. NOTE: Structural screw can be driven with T-bits.



8 **REVIEWED**
All roofing manufacturers' written instructions must also be followed by anyone modifying a roof system. Consult the roof manufacturer's specs and instructions prior to working on the roof.




LANNING DIVISION

OFFICE: 2800 N. GARDEN


Simplified Grounding for Every Application

The UFO family of components eliminates the need for separate grounding hardware by bonding solar modules directly to IronRidge XR Rails. All system types that feature the UFO family—Flush Mount, Tilt Mount and Ground Mount—are fully listed to the UL 2703 standard.

UFO hardware forms secure electrical bonds with both the module and the rail, resulting in many parallel grounding paths throughout the system. This leads to safer and more reliable installations.



System Diagram



Approved Enphase microinverters can provide equipment grounding of IronRidge systems, eliminating the need for grounding lugs and field installed equipment ground conductors (EGC). A minimum of two microinverters mounted to the same rail and connected to the same Engage cable is required. Refer to installation manuals for additional details.

UL Certification

The IronRidge Flush Mount, Tilt Mount, and Ground Mount Systems have been listed to UL 2703 by Intertek Group plc.

UL 2703 is the standard for evaluating solar mounting systems. It ensures these devices will maintain strong electrical and mechanical connections over an extended period of time in extreme outdoor environments.

Feature	Cross-System Compatibility			
	Flush Mount	Tilt Mount	Ground Mount	Ground Mount
XR Rails	✓	✓	✓	XR1000 Only
UFO/Stopper	✓	✓	✓	✓ * Limited operation
BOSS™ Splice	✓	✓	✓	✓
Grounding Lug	1 per Row	1 per Row	1 per Row	1 per Row
Micro-Inverters	Enphase - M250-72, M250-60, M215-Darwin - M1G240, M1G300, G320	✓	✓	✓
Power & Fire Rating	Class A	Class A	Class A	Class A




Go to IronRidge.com/UFO
Tested or Evaluated with over 400 Framed Modules. Refer to installation manuals for a detailed list.

Enphase IQ Combiner 4/4C

X-IQ-AM1-240-4

X-IQ-AM1-240-4C



To learn more about Enphase offerings, visit enphase.com

The **Enphase IQ Combiner 4/4C** with Enphase IQ Gateway and integrated LTE-M1 cell modem (included only with IQ Combiner 4C) consolidates interconnection equipment into a single enclosure and streamlines IQ microinverters and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

Smart

- Includes IQ Gateway for communication and control
- Includes Enphase Mobile Connect cellular modem (CELLMODEM-M1-06-SP-05), included only with IQ Combiner 4C
- Includes solar shield to match Enphase IQ Battery aesthetics and deflect heat
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge monitoring

Simple

- Centered mounting brackets support single stud mounting
- Supports bottom, back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA Type 3R enclosure
- Five-year limited warranty
- Two years labor reimbursement program coverage included for both the IQ Combiner SKU's
- UL listed



Enphase IQ Combiner 4/4C

MODEL NUMBER
IQ Combiner 4 (X-IQ-AM1-240-4)

IQ Combiner 4C (X-IQ-AM1-240-4C)

ACCESSORIES AND REPLACEMENT PARTS

- Enphase Communications Kit
- COMMS-CELLMODEM-M1-06
- CELLMODEM-M1-06-SP-05
- CELLMODEM-M1-06-AT-05
- Cellular Ethernet
- BRK-15A-2P-240V
- BRK-20A-2P-240V
- BRK-15A-2P-240V-B
- BRK-20A-2P-240V-B
- EPLC-01
- XA-SOLARSHIELD-ES
- XA-PLUG-120-3
- XA-ENV-FCBK-3
- X-IQ-MA-HD-12BA

ELECTRICAL SPECIFICATIONS

Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating	65 A
Max. continuous current rating (based from PV storage)	64 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (input and/or storage)	Up to four, 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)
Max. total branch circuit breaker rating (input)	80A of distributed generation / 95A with IQ Gateway breaker included
Production metering CT	200 A solid core pre-installed and wired to IQ Gateway
Consumption monitoring CT (CT-500-SPLIT)	A pair of 200 A split core current transformers

MECHANICAL DATA

Dimensions (WxHxD)	37.5 x 49.5 x 16.8 cm (14.75" x 19.5" x 6.63") Height is 21.06" (53.5 cm) with mounting brackets
Weight	7.5 kg (16.5 lb)
Ambient temperature range	-40° C to 44° C (-40° to 111° F)
Cooling	Natural convection, plus heat shield
Enclosure environment rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	<ul style="list-style-type: none"> 20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors 80 A breaker branch input: 10 AWG copper conductors 100 A breaker branch input: 8 AWG copper conductors Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing. To 2000 meters (6,560 feet)

INTERNET CONNECTION OPTIONS

Integrated Wi-Fi	802.11b/g/n
Cellular	Mobile Connect (M1-06-SP-05) for all Enphase installations, Optional 802.3 Cat6 (or Cat 6) Ethernet cable (not included)
Ethernet	UL 1741, CANS/CSA C22.2 No. 107.1, 47 CFR Part 15, Class B, ICES 003 (Production)
Compliance, IQ Combiner	UL 60601-1/CAN/CSA 22.2 No. 610-01
Compliance, IQ Gateway	UL 60601-1/CAN/CSA 22.2 No. 610-01

To learn more about Enphase offerings, visit enphase.com

© 2023 Enphase Energy, All rights reserved. ENPHASE, the ENPHASE logo, Enphase Energy, the Enphase logo, IQ Combiner 4/4C, and other names are trademarks of Enphase Energy, Inc. Data subject to change 10/2/2023

IQ Combiner 4 with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI ICS 12.20-7-0.5%) and consumption monitoring (ANSI ICS 12.20-7-0.5%) includes a silver solar shield to match the IQ Battery system and IQ Combiner 4C with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI ICS 12.20-7-0.5%) and consumption monitoring (ANSI ICS 12.20-7-0.5%), a plug-and-play industrial grade cell modem (for systems up to 60 microinverters, available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is adequate cellular service in the installation area) includes a silver solar shield to match the IQ Battery and IQ System Controller, and to deflect heat.

(not included, order separately)

- Include COMMS-M1-01 and CELLMODEM-M1-06-SP-05 with 5-year Sprint data plan for Ensemble sites
- 40 based LTE-M1 cellular modem with 5-year Sprint data plan
- 40 based LTE-M1 cellular modem with 5-year AT&T data plan
- Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers.
- Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers.
- Circuit breaker: 2 pole, 15A, Eaton BR215
- Circuit breaker: 2 pole, 20A, Eaton BR220
- Circuit breaker: 2 pole, 15A, Eaton BR215B with hold down tilt support
- Circuit breaker: 2 pole, 20A, Eaton BR220B with hold down tilt support
- Power line carrier (communication bridge pair), quantity - one pair
- Replacement solar shield for IQ Combiner 4/4C
- Accessory receptacle for Power Line Carrier in IQ Combiner 4/4C (required for EPLC-01)
- Replacement IQ Gateway printed circuit board (PCB) for Combiner 4/4C
- Hold down kit for Eaton circuit breaker with screws.

ELECTRICAL SPECIFICATIONS

Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating	65 A
Max. continuous current rating (based from PV storage)	64 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (input and/or storage)	Up to four, 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)
Max. total branch circuit breaker rating (input)	80A of distributed generation / 95A with IQ Gateway breaker included
Production metering CT	200 A solid core pre-installed and wired to IQ Gateway
Consumption monitoring CT (CT-500-SPLIT)	A pair of 200 A split core current transformers

MECHANICAL DATA

Dimensions (WxHxD)	37.5 x 49.5 x 16.8 cm (14.75" x 19.5" x 6.63") Height is 21.06" (53.5 cm) with mounting brackets
Weight	7.5 kg (16.5 lb)
Ambient temperature range	-40° C to 44° C (-40° to 111° F)
Cooling	Natural convection, plus heat shield
Enclosure environment rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	<ul style="list-style-type: none"> 20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors 80 A breaker branch input: 10 AWG copper conductors 100 A breaker branch input: 8 AWG copper conductors Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing. To 2000 meters (6,560 feet)

INTERNET CONNECTION OPTIONS

Integrated Wi-Fi	802.11b/g/n
Cellular	Mobile Connect (M1-06-SP-05) for all Enphase installations, Optional 802.3 Cat6 (or Cat 6) Ethernet cable (not included)
Ethernet	UL 1741, CANS/CSA C22.2 No. 107.1, 47 CFR Part 15, Class B, ICES 003 (Production)
Compliance, IQ Combiner	UL 60601-1/CAN/CSA 22.2 No. 610-01
Compliance, IQ Gateway	UL 60601-1/CAN/CSA 22.2 No. 610-01

To learn more about Enphase offerings, visit enphase.com

© 2023 Enphase Energy, All rights reserved. ENPHASE, the ENPHASE logo, Enphase Energy, the Enphase logo, IQ Combiner 4/4C, and other names are trademarks of Enphase Energy, Inc. Data subject to change 10/2/2023



PLANNING DIVISION



making solar simple.

A. System Specifications and Ratings

- Maximum Voltage: 600 Volts
- Maximum Current: 60 Amps
- Allowable Wire: 14 AWG – 6 AWG
- Spacing: Please maintain a spacing of at least 1/2" between uninsulated live parts and fittings for conduit, armored cable, and uninsulated live parts of opposite polarity.
- Enclosure Rating: Type 3R
- Roof Slope Range: 2.5 – 12:12
- Max Side Wall Fitting Size: 1"
- Max Floor Pass-Through Fitting Size: 1"
- Ambient Operating Conditions: (-35°C) - (+75°C)
- Compliance:
 - JB-1: UL1741
 - Approved wire connectors: must conform to UL1741
- System Marking: **Interek Symbol and File #5015705**
- Periodic Re-inspections: If re-inspections yield loose components, loose fasteners, or any corrosion between components, components that are found to be affected are to be replaced immediately.

Table 1: Typical Wire Size, Torque Loads and Ratings

	1 Conductor		2 Conductor		Torque		
	Type	NM	Type	NM	Inch Lbs	Volts	Current
ABB Z56 terminal block	10-24 awg	0.5-0.7	16-24 awg	0.5-0.7	6.2-8.85	600V	30 amp
ABB Z510 terminal block	6-24 awg	1.0-1.6	12-20 awg	1.0-1.6	8.85-14.16	600V	40 amp
ABB Z516 terminal block	4-24 awg	1.6-2.4	10-20 awg	1.6-2.4	14.6-21.24	600V	60 amp
ABB M6/8 terminal block	8-22 awg	.08-1	Sol/Str	.08-1	8.85	600V	50 amp
Ideal 452 Red WING-NUT Wire Connector	8-18 awg		Sol/Str			600V	
Ideal 451 Yellow WING-NUT Wire Connector	10-18 awg		Sol/Str			600V	
Ideal, In-Sure Push-In Connector Part #39	10-14 awg		Sol/Str			600V	
WAGO, 221-612	10-14 awg		Sol/Str			600V	
International Hydraulics 252/0	10-14 awg	4	Sol/Str	4	35		
	8 awg	4.5	Sol/Str	4.5	40		
Brumall 4-5,3	4-6 awg		Sol/Str		45		2000V
	10-14 awg		Sol/Str		35		
Blackburn LL414	4-14 awg		Sol/Str				


Table 2: Minimum wire-bending space for conductors through a wall opposite terminals in mm (inches)

Wire size, AWG or kcmil	Wires per terminal (pole)					
	mm	(inch)	mm	(inch)	mm	(inch)
14-10 (2.1-5.3)	Not specified					
8 (8.4)	38.1	1-1/2				
6 (13.3)	50.8	(2)				

REVIEWED
Sep 01, 2023

INTERWEST CONSULTING GROUP

COMPILED BY THE REVIEW AND NOT APPROVED CONSTRUCTION TO PROCEED IN
VIOLATION OF PERMITS, STATE OR LOCAL REGULATIONS.



IRONRIDGE

Class A Fire Rating

Background

All roofing products are tested and classified for their ability to resist fire. Recently, these fire resistance standards were expanded to include solar equipment as part of the roof system. Specifically, this requires the modules, mounting hardware and roof covering to be tested together as a system to ensure they achieve the same fire rating as the original roof covering. These new requirements are being adopted throughout the country in 2016.

IronRidge Certification

IronRidge was the first company to receive a Class A Fire Rating – the highest possible rating – from Intertek Group plc., a Nationally Recognized Testing Laboratory. IronRidge Flush Mount and Tilt Mount Systems were tested on sloped and flat roofs in accordance with the new UL 1703 & UL 2703 test standards. The testing evaluated the system's ability to resist flame spread, burning material and structural damage to the roof. Refer to the table below to determine the requirements for achieving a Class A Fire Rating on your next project.


System	Roof Slope	Module	Fire Rating*
Flush Mount 	Any Slope	Type 1, 2, & 3	Class A
Tilt Mount 	≤ 9.5 Degrees	Type 1, 2, & 3	Class A

*Class A rated PV systems can be installed on Class A, B, and C roof.

Fire Testing Process


- Test Setup**
Solar Modules are given a Type classification based on their materials and construction.
- Mounting System**
Mounting is tested as part of a system that includes type-tested modules and fire-rated roof covering.
- Roof Covering**
Roof covering products are given a Fire Class Rating of A, B or C based on their tested fire resistance.

Burning Brand Test



A burning wooden block is placed on module as a fan blows at 12 mph. Flame cannot be seen on underside of roof within 90 minutes.

Spread of Flame Test



Flame at southern edge of roof is aimed up the roof as a fan blows at 12 mph. The flame cannot spread 6 feet or more in 10 minutes.

Frequently Asked Questions

What is a "module type"?

The new UL 1703 standard introduces the concept of a PV module type, based on 4 construction parameters and 2 fire performance parameters. The purpose of this classification is to certify mounting systems without needing to test it with every module.

What roofing materials are covered?

All fire rated roofing materials are covered within this certification including composition shingle, clay and cement tile, metal, and membrane roofs.

What if I have a Class C roof, but the jurisdiction now requires Class A or B?

Generally, older roofs will typically be "grandfathered in", and will not require re-roofing. However, if 50% or more of the roofing material is replaced for the solar installation the code requirement will be enforced.

Where is the new fire rating requirement code listed?

2012 IBC: 1509.7.2 Fire Classification, Rooftop mounted photovoltaic systems shall have the same fire classification as the roof assembly required by Section 1505.

Where is a Class A Fire Rating required?

The general requirement for roofing systems in the IBC refers to a Class C fire rating. Class A or B is required for areas such as Wildland Urban Interface areas (WUI) and for very high fire severity areas. Many of these areas are found throughout the western United States. California has the most Class A and B roof fire rating requirements, due to wild fire concerns.

Are standard mid clamps covered?

Mid clamps and end clamps are considered part of the PV "system", and are covered in the certification.

What attachments and flashings are deemed compatible with Class A?

Attachments and their respective flashings are not constituents of the rating at this time. All code-compliant flashing methods are acceptable from a fire rating standpoint.

What mounting height is acceptable?

UL fire testing was performed with a gap of 5", which is considered worst case in the standard. Therefore, the rating is applicable to any module to roof gap.

Am I required to install skirting to meet the fire code?

No, IronRidge achieved a Class A fire rating without any additional racking components.

What determines Fire Classification?

Fire Classification refers to a fire-resistance rating system for roof covering materials based on their ability to withstand fire exposure.

- Class A - effective against severe fire exposure
- Class B - effective against moderate fire exposure
- Class C - effective against light fire exposure

What if the roof covering is not Class A rated?

The IronRidge Class A rating will not diminish the fire rating of the roof, whether Class A, B, or C.

What tilt is the tilt mount system fire rated for?

The tilt mount system is rated for 1 degree and up and any roof to module gap, or mounting height.

REVIEWED
Sep 01, 2023

More Resources

INTERWEST CONSULTING GROUP



Installation Manuals
Visit our website for manuals that include UL 2703 Listing and Fire Rating Classification.
Go to IronRidge.com



Engineering Certification Letters
We offer complete engineering resource and pre-stamped certification letters.
Go to IronRidge.com

